CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7300-1615:131 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450

Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Models *SM-12/24-R, *SMX-12/24-R, *DSM-12/24-R and *DSMX-12/24-R Synchronized

Control Modules.

Refer to listee's data sheet for additional detailed product description and operational

considerations.

RATING: 10.5 - 31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as signaling appliances accessory for use with separately listed synchronized strobe

lights. For indoor use only.

NOTE: Formerly 7300-0801:157

XL: 7300-0785:132

*Rev. 08-22-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 29, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division